

**MATERIAL REACTION TO FIRE CLASSIFICATION REPORT
PROVIDED TO ARTICLE 5 OF THE FRENCH OFFICE
REGULATION DATED NOVEMBER 21st, 2002**

Valid 5 years from the date of delivery

REPORT N° MZC-08-1195M

and appendix of 4 pages

MATERIAL presented by : DHJ INTERNATIONAL
1, rue de Morat – B.P. n° 8
67600 SELESTAT

TRADE NAME : DECOPRINT STRETCH

BRIEF DESCRIPTION : Knitted fabric for ink jet printing, 98% Polyester – 2% Lycra , with an acrylic coating fireproofed by impregnation, on the right side
Nominal surface density : 145 g/m²
Nominal thickness : 0,25 mm
Colour: white

TEST REPORT : N° MZC-08-1195 of February 25th 2008

TESTS : Electrical burner test
Flame persistence test

CLASSIFICATION

M 1

CLASSIFICATION DURATION (article 5 of appendix 2) : limited 12 months from the date of the setting of the material in the regulated building (no washable material, no dry cleaning)

Given the criteria resulting from the tests described in the enclosed test report.
The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994. Compliance can only be attested by qualification certificates recognised by the French Ministry for Industry and particularly with the NF fire resistance standard.
N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Mazamet, France, on February 25th, 2008

Director or empowered person

Richard RICO

Responsible for the test

Sandrine PANIS



ACCREDITATION
N° 1-0513*
PORTÉE
COMMUNIQUÉE
SUR DEMANDE

Direction Régionale Sud-Ouest
Boulevard du Thoré – 81200 AUSSILLON – MAZAMET
Tél. (33) 05 63 97 56 90 – Fax (33) 05 63 97 56 91
SIRET 433 430 832 00082