

**MATERIAL REACTION TO FIRE CLASSIFICATION REPORT
PROVIDED TO ARTICLE 5 OF THE FRENCH OFFICE
REGULATION DATED NOVEMBER 21st, 2002**

Valid 5 years from the date of delivery

REPORT N° MZC-09-1832M

and appendix of 4 pages

MATERIAL presented by DHJ INTERNATIONAL
1, rue de Morat – B.P. n° 8
67601 SELESTAT Cedex

TRADE NAME : DECOPRINT THEATER

BRIEF DESCRIPTION : Fabric used as printing support 100% polyester with acrylic
coating fireproofed by impregnation.
Nominal surface density : 290 g/m²
Nominal thickness : 0,22 to 0,24 mm
Colour : white

TEST REPORT : N° MZC-09-1832 of July 27th 2009

TESTS : Electrical burner test
Flame persistence test

CLASSIFICATION


M 1

**CLASSIFICATION DURATION (article 5 of appendix 2) : limited 12 months from the date
when the product is putting in the regulated building (no washable material,
no dry cleaning)**


Given the criteria resulting from the tests described in the enclosed test report.
The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a
qualification certificate as defined by French law dated June 3, 1994. Compliance can only be attested by qualification certificates recognised
by the French Ministry for Industry and particularly with the NF fire resistance standard.
To declare, or not, the correspondence to the specification, it was not explicitly taken account the uncertainty associated with the result
N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the
classification report and enclosed test report.


Issued in Mazamet, France, on July 27th, 2009

Director or empowered person


Richard RICO

Responsible for the test


Sandrine PANIS



ACCREDITATION
N° 1-0513*
Portée disponible
sur www.cofrac.fr

Direction Régionale Sud-Ouest
Boulevard du Thoré - 81200 AUSSILLON – MAZAMET
Tél. (33) 05 63 97 56 90 – Fax (33) 05 63 97 56 91
SIRET 433 430 832 00082